



Consumer Confidence Report for Calendar Year 2023

Este informe contiene información muy importante sobre el agua usted bebe.
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name		
AZ04-13-137	Chino Valley Town of		
Contact Name and Title	Phone Number	E-mail Address	
Joe Grassi Utilities Operator	928-636-6084	jgrassi@chinoaz.net	
<p>We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Jesse Holyfield</u> at <u>928-636-6084</u> for additional opportunity and meeting dates and times.</p>			

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s): Groundwater

Drinking Water Contaminants

Microbial Contaminants: Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Inorganic Contaminants: Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Pesticides and Herbicides: Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

Organic Chemical Contaminants: Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants: That can be naturally occurring or be the result of oil and gas production and mining activities.

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

This PWS did not receive a SWAP because the PWS was either inactive at the time or the PWS did not exist. Further source water assessment documentation can be obtained by contacting ADEQ.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water

Maximum Contaminant Level Goal MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health

Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method

Millirems per year (MREM): A measure of radiation absorbed by the body

Not Applicable (NA): Sampling was not completed by regulation or was not required

Not Detected (ND or <): Not detectable at reporting limit

Nephelometric Turbidity Units (NTU): A measure of water clarity

Million fibers per liter (MFL)

Picocuries per liter (pCi/L): Measure of the radioactivity in water

ppm: Parts per million or Milligrams per liter (mg/L)

ppb: Parts per billion or Micrograms per liter (µg/L)

ppt: Parts per trillion or Nanograms per liter (ng/L)

ppq: Parts per quadrillion or Picograms per liter (pg/L)

ppm x 1000 = ppb

ppb x 1000 = ppt

ppt x 1000 = ppq

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. **The Town of Chino Valley** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination
E. Coli	N	0	0	0	0	Human and animal fecal waste
Fecal Indicator (From GWR source) (coliphage, enterococci and/or E. coli)	N	0	0	0	0	Human and animal fecal waste
Surface Water Treatment Rule	TT Violation Y or N	Highest Level Detected	% Range (Low-High)	TT	Sample Month & Year	Likely Source of Contamination
Total Organic Carbon ¹ (mg/L) If Conventional Filtration	N/A	N/A	N/A	TT		Naturally Present in the Environment
Turbidity ² (NTU)	N/A	N/A	N/A	TT		Soil runoff

¹ Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THM) and haloacetic acids (HAA). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver, or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

² Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. We monitor it because it is a good indicator of the quality of water. High turbidity can hinder the effectiveness of disinfectants. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	1.23	0.43-2.10	4	4	Daily 23	Water additive used to control microbes
Chlorine dioxide (ppb) if treated with CLO2	N/A	N/A	N/A	800	0		Water additive used to control microbes

Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	ND	ND	60	N/A	Aug '23	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	8.2	8.2	80	N/A	Aug '23	Byproduct of drinking water disinfection
Bromate (ppb) <small>if treated with Ozone</small>	N/A	N/A	N/A	10	0		Byproduct of drinking water disinfection
Chlorite (ppm) <small>if treated with ClO2</small>	N/A	N/A	N/A	1	0.8		Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90 th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	0.077	0	1.3	1.3	Aug '23	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	ND	0	15	0	Aug'23	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Beta/Photon Emitters (mrem/yr.)	N/A	N/A	N/A	4	0		Decay of natural and man-made deposits
Alpha Emitters (pCi/L) <small>(This is Gross Alpha 4000)</small>	N	ND	ND	15	0	Aug '15	Erosion of natural deposits
Combined Radium-226 & -228 (pCi/L)	N	1.5	1.5	5	0	Aug '23	Erosion of natural deposits
Uranium (ug/L)	N	ND	ND	30	0	Aug '15	Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Antimony (ppb)	N	ND	ND	6	6	Jul '22	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
Arsenic ¹ (ppb)	N	5.2	5.2	10	0	Jul '22	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Asbestos (MFL)	N	ND	ND	7	7	Jul '22	Decay of asbestos cement water mains; Erosion of natural deposits
Barium (ppm)	N	.0021	.0021	2	2	Jul '22	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N	ND	ND	4	4	Jul '22	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N	ND	ND	5	5	Jul '22	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N	5.3	5.3	100	100	Jul '22	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	N	ND	ND	200	200	Jul '22	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	N	2.8	2.8	4	4	Jul '22	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppb)	N	ND	ND	2	2	Jul '22	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland.
Nitrate ² (ppm)	N/N	2.27	Epds1 1.80 Epds2 2.40	10	10	Aug '23	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (ppm)	N	ND	ND	1	1	Aug '23	Runoff from fertilizer use; leaching from septic tanks,

							sewage; erosion of natural deposits
Selenium (ppb)	N	ND	ND	50	50	Jul '22	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N	16	16	N/A	N/A	Jul '22	Erosion of natural deposits
Thallium (ppb)	N	ND	ND	2	0.5	Jul '22	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

¹ **Arsenic** is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

² **Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

Synthetic Organic Chemicals (SOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
2,4-D (ppb)	N	ND	ND	70	70	Jul '22	Runoff from herbicide used on row crops
2,4,5-TP (a.k.a. Silvex) (ppb)	N	ND	ND	50	50	Jul '22	Residue of banned herbicide
Acrylamide	N	ND	ND	TT	0	Jul '19	Added to water during sewage / wastewater treatment
Alachlor (ppb)	N	ND	ND	2	0	Jul '22	Runoff from herbicide used on row crops
Atrazine (ppb)	N	ND	ND	3	3	Jul '22	Runoff from herbicide used on row crops
Benzo (a) pyrene (PAH) (ppt)	N	ND	ND	200	0	Jul '22	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	N	ND	ND	40	40	Jul '22	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	N	ND	ND	2	0	Jul '22	Residue of banned termiticide
Dalapon (ppb)	N	ND	ND	200	200	Jul '22	Runoff from herbicide used on rights of way
Di (2-ethylhexyl) adipate (ppb)	N	ND	ND	400	400	Jul '22	Discharge from chemical factories
Di (2-ethylhexyl) phthalate (ppb)	N	ND	ND	6	0	Jul '22	Discharge from rubber and chemical factories
Dibromochloropropane (ppt)	N	ND	ND	200	0	Jul '22	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb (ppb)	N	ND	ND	7	7	Jul '22	Runoff from herbicide used on soybeans and vegetables
Diquat (ppb)	N			20	20		Runoff from herbicide use
Dioxin [a.k.a. 2,3,7,8-TCDD] (ppq)	N/A	N/A	N/A	N/A	N/A		Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall (ppb)	N	ND	ND	100	100	Jul '22	Runoff from herbicide use
Endrin (ppb)	N	ND	ND	2	2	Jul '22	Residue of banned insecticide
Epichlorohydrin	N	ND	ND	TT	0	Jul '19	Discharge from industrial chemical factories; an impurity of some water treatment chemicals
Ethylene dibromide (ppt)	N	ND	ND	50	0	Jul '22	Discharge from petroleum refineries
Glyphosate (ppb)	N	ND	ND	700	700	Jul '22	Runoff from herbicide use
Heptachlor (ppt)	N	ND	ND	400	0	Jul '22	Residue of banned termiticide
Heptachlor epoxide (ppt)	N	ND	ND	200	0	Jul '22	Breakdown of heptachlor
Hexachlorobenzene (ppb)	N	ND	ND	1	0	Jul '22	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclo pentadiene (ppb)	N	ND	ND	50	50	Jul '22	Discharge from chemical factories
Lindane (ppt)	N	ND	ND	200	200	Jul '22	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	N	ND	ND	40	40	Jul '22	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa
Oxamyl (a.k.a. Vydate) (ppb)	N	ND	ND	200	200	Jul '22	Runoff/leaching from insecticide used on apples, potatoes and tomatoes

PCBs [Polychlorinated biphenyls] (ppt)	N	ND	ND	500	0	Aug '01	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	N	ND	ND	1	0	Jul '22	Discharge from wood preserving factories
Picloram (ppb)	N	ND	ND	500	500	Jul '22	Herbicide runoff
Simazine (ppb)	N	ND	ND	4	4	Jul '22	Herbicide runoff
Toxaphene (ppb)	N	ND	ND	3	0	Jul '22	Runoff/leaching from insecticide used on cotton and cattle
Volatile Organic Chemicals (VOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Benzene (ppb)	N	ND	ND	5	0	Aug '23	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	N	ND	ND	5	0	Aug '23	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	N	ND	ND	100	100	Aug '23	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	N	ND	ND	600	600	Aug '23	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	N	ND	ND	75	75	Aug '23	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	N	ND	ND	5	0	Aug '23	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	N	ND	ND	7	7	Aug '23	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	N	ND	ND	70	70	Aug '23	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	N	ND	ND	100	100	Aug '23	Discharge from industrial chemical factories
Dichloromethane (ppb)	N	ND	ND	5	0	Aug '23	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	N	ND	ND	5	0	Aug '23	Discharge from industrial chemical factories
Ethylbenzene (ppb)	N	ND	ND	700	700	Aug '23	Discharge from petroleum refineries
Styrene (ppb)	N	ND	ND	100	100	Aug '23	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	N	ND	ND	5	0	Aug '23	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	N	ND	ND	70	70	Aug '23	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	N	ND	ND	200	200	Aug '23	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	N	ND	ND	5	3	Aug '23	Discharge from industrial chemical factories
Trichloroethylene (ppb)	N	ND	ND	5	0	Aug '23	Discharge from metal degreasing sites and other factories
Toluene (ppm)	N	ND	ND	1	1	Aug '23	Discharge from petroleum factories
Vinyl Chloride (ppb)	N	ND	ND	2	0	Aug '23	Leaching from PVC piping; discharge from chemical factories
Xylenes (ppm)	N	ND	ND	10	10	Aug '23	Discharge from petroleum or chemical factories

Water Quality Table – Unregulated Contaminants

Your drinking water was sampled for the presence and concentration of 29 different per- and polyfluoroalkyl substances, some known by the acronyms PFAS, PFOA, PFNA, PFHxS, PFBS, and GenX, a group of contaminants in the final stages of becoming regulated by the EPA. PFAS are man-made chemicals that are resistant to heat, water, and oil. They have been used since the 1940s to manufacture various consumer products, including fire-fighting foam and stain resistant, water-resistant, and nonstick items. Many PFAS do not break down easily and can build up in people, animals, and the environment over time. Scientific studies have shown that exposure to certain PFAS can be harmful to people and animals, depending on the level and duration of [exposure](#).

To learn more about this group of chemicals, we encourage you to read the ADEQ-provided “PFAS 101 Fact Sheet” and to visit the ADEQ website at <https://www.azdeq.gov/pfas-resources>

Per- and Polyfluoroalkyl Substances	Highest Level Detected	Range of All Samples	Proposed MCL
PFOA (in parts per trillion)	8.77	3.09-8.77	4.0 ppt
PFOS (in parts per trillion)	ND	ND	4.0 ppt
PFNA (in parts per trillion)	ND	ND	N/A*
PFHxS (in parts per trillion)	6.93	3.12-6.93	N/A*
PFBS (in parts per trillion)	3.34	3.24-3.34	N/A*
GenX (in parts per trillion)	ND	ND	N/A*
Calculated Hazard Index (HI)			1 (no units)

* EPA is proposing a Hazard Index MCL to limit any mixture containing one or more of PFNA, PFHxS, PFBS, and/or GenX Chemicals. The Hazard Index considers the different toxicities of PFNA, GenX Chemicals, PFHxS, and PFBS. For these PFAS, water systems would use a hazard index calculation to determine if the combined levels of these PFAS in the drinking water at that system pose a potential risk and require action (Source: EPA Fact Sheet: Understanding the PFAS National Primary Drinking Water Proposal Hazard Index).

Water Quality Table - Unregulated Contaminant Monitoring Rule (Required Reporting)

Twenty-nine Per- and Polyfluoroalkyl Substances (In parts per trillion)	Detected (Y/N)	Average of Results (ppt)	Range of All Samples (Low-High)	Minimum Reporting Level (ppt)	Analytical Methods
11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	N			5	EPA 533
1H, 1H, 2H, 2H-perfluorodecane sulfonic acid (8:2 FTS)	N			5	EPA 533
1H, 1H, 2H, 2H-perfluorohexane sulfonic acid (4:2 FTS)	N			3	EPA 533
1H, 1H, 2H, 2H-perfluorooctane sulfonic acid (6:2 FTS)	N			5	EPA 533
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	N			3	EPA 533
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	N			2	EPA 533
hexafluoropropylene oxide dimer acid (HFPO-DA) (GenX)	N			5	EPA 533
nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	N			20	EPA 533
perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	N			3	EPA 533
Perfluoro-3-methoxypropanoic acid (PFMPA)	N			3	EPA 533
Perfluoro-4-methoxybutanoic acid (PFMBA)	N			4	EPA 533
Perfluorobutanesulfonic acid (PFBS)	Y	2.95	2.95	3	EPA 533
Perfluorobutanoic acid (PFBA)	N			5	EPA 533
Perfluorodecanoic acid (PFDA)	N			3	EPA 533
Perfluorododecanoic acid (PFDoA)	N			3	EPA 533
Perfluoroheptanesulfonic acid (PFHpS)	N			3	EPA 533
Perfluoroheptanoic acid (PFHpA)	Y	2.75	2.75	3	EPA 533
Perfluorohexanesulfonic acid (PFHxS)	Y	5.74	5.74	3	EPA 533
Perfluorohexanoic acid (PFHxA)	Y	8.00	8.00	3	EPA 533
Perfluorononanoic acid (PFNA)	N			4	EPA 533
Perfluorooctanesulfonic acid (PFOS)	N			4	EPA 533
Perfluorooctanoic acid (PFOA)	Y	7.74	7.74	4	EPA 533

Perfluoropentanesulfonic acid (PFPeS)	N			4	EPA 533
Perfluoropentanoic acid (PFPeA)	Y	9.62	9.62	3	EPA 533
Perfluoroundecanoic acid (PFUnA)	N			2	EPA 533
n-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND			5	EPA 537.1
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND			6	EPA 537.1
Perfluorotetradecanoic acid (PFTA)	ND			8	EPA 537.1
Perfluorotridecanoic acid (PFTrDA)	ND			7	EPA 537.1
One Metal	Detected (Y/N)	Average	Range of All Samples (Low-High)	MRL (ppb)	Analytical Methods
Lithium (ppb)	N/A	N/A	N/A	9 µg/L	EPA 200.7, SM 3120 B, ASTM D1976-20

Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
Reporting failure	Forgot to send MRDL reports	17 days	Sent MRDL reports to ADEQ
Missed monitoring	Missed sampling VOC's at EPDS 2	4 th Quarter	Sampled the next quarter
Reporting failure	Forgot to send Lead consumer notice	4 th Quarter	Sent LCN to ADEQ for compliance

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Health Effects Information

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a the mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

System Monitoring and Testing

The data presented in the report are from the most recent round of sampling. Not all contaminants are tested each year. Chlorine residual samples are tested daily, microbiological samples are tested monthly. Lead and copper are tested on a 3 year cycle. VOC's, IOC's and SOC's are tested on a 9 year cycle. The 90th percentile is arrived at by taking the highest two results adding them together and dividing by two.

In Conclusion

We have learned through our monitoring and testing that some contaminants have been detect. The Town is working to select treatment methods that will bring levels below the MCL. The Town of Chino Valley Utilities department work to provide top quality water to every customer. We ask that all our customers help is protect our water sources, which is at the heart of our community.