

## Consumer Confidence Report for Calendar Year 2024

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

<https://espanol.epa.gov/espanol/recursos-e-informacion-sobre-el-ccb-para-los-consumidores>

| Public Water System ID Number  | Public Water System Name |                     |  |
|--|--------------------------|---------------------|--|
| AZ04-13137   | Town of Chino Valley     |                     |  |
| Contact Name and Title   | Phone Number             | E-mail Address      |  |
| Joe Grassi- Utilities Operator   | 928-636-6084             | jgrassi@chinoaz.net |  |
| We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Jesse Holyfield</u> at <u>928-636-6084</u> for additional opportunity and meeting dates and times. You may also visit our website at <a href="https://www.chinoaz.net/192/Water-Quality">https://www.chinoaz.net/192/Water-Quality</a> |                          |                     |  |

This is our annual report about your drinking water quality, also called a Consumer Confidence Report or CCR. Having clean, safe water is one of the most important services we provide, and we want you to be as informed as possible about your drinking water.

This report provides you with information about where your water comes from, results of sampling that we have performed, and any issues or violations that happened over the previous year. This water quality report includes a table with the most recent water testing results within the last 5 years. The table shows if different germs and chemicals were in a safe range and met EPA's health standards. Look for the column in the table called "TT or MCL violation," to see if your utility found unsafe levels of any germs or chemicals.

You may also find real-time information about our water system at the Arizona Department of Environmental Quality (ADEQ) *Drinking Water Watch* website at [https://azsdwis.azdeq.gov/DWW\\_EXT/](https://azsdwis.azdeq.gov/DWW_EXT/)

### Drinking Water Sources

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Our water source(s):** [Groundwater wells drawing from \(Little Chino Sub Basin\)](#)

### Source Water Assessment

Making the water safe to drink starts by protecting the place it comes from. We work with state scientists at the Arizona Department of Environmental Quality (ADEQ) to examine water at its source to look for possible pollutants. This is called a Source Water Assessment (SWA).

Based on the information available at the time of the assessment on the hydrogeology and land uses around the drinking water source(s) of this public water system, the Arizona Department of Environmental Quality (ADEQ) has given a low vulnerability designation for the degree to which this public water system drinking water source(s) are protected.

A low vulnerability designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection. Further source water assessment information can be found on ADEQ's website: <https://azdeq.gov/source-water-protection>

## Drinking Water Contaminants

Contaminants are any physical, chemical, biological, or radiological substance or matter in water. Contaminants that may be present in source water include:

**Microbial Contaminants:** such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic Contaminants:** such as salts and metals, which can occur naturally in the soil or groundwater or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides:** which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic Chemical Contaminants:** including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

**Radioactive Contaminants:** including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

## Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

More information about contaminants, their potential health effects, and the appropriate means to lessen the risk can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 800-426-4791 or visiting the website [epa.gov/safewater](http://epa.gov/safewater).

## Definitions

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Level 1 Assessment:** A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

## Lead Informational Statement

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

The Town of Chino Valley is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk.

Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water.

To address lead in drinking water, public water systems were required to develop and maintain an inventory of service line materials by Oct 16, 2024. Developing an inventory and identifying the location of lead service lines (LSL) is the first step for beginning LSL replacement and protecting public health. The lead service inventory may be viewed online at: [www.chinoaz.net](http://www.chinoaz.net). Please contact us or visit <https://www.chinoaz.net/626/Lead-Copper-Rule-Information> if you would like more information about the inventory or any lead sampling that has been done.

If you are concerned about lead in your water and wish to have your water tested, contact [Jesse Holyfield TOCV Utilities 928-636-608](tel:928-636-608). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

## Water Quality Data – Regulated Contaminants

The following are terms related to water quality data presented in this table:

**Not Applicable (NA):** Sampling was not completed because it was not required by regulation.

**Not Detected (ND or <):** Not detectable at reporting limit.

**Minimum Reporting Limit (MRL):** The smallest concentration of a substance that can be reliably measured by a given analytical method.

**Millirems per year (MREM):** A measure of radiation absorbed by the body.

**Nephelometric Turbidity Units (NTU):** Measure of water clarity.

**Million fibers per liter (MFL):** Measure of asbestos fibers.

**Picocuries per liter (pCi/L):** Measure of the radioactivity in water.

**ppm:** Parts per million or Milligrams per liter (mg/L), equal to 1/1000 of a gram.

**ppb:** Parts per billion or Micrograms per liter (µg/L), equal to 1000 ppm.

**ppt:** Parts per trillion or Nanograms per liter (ng/L), equal to 1000 ppb.

**ppq:** Parts per quadrillion or Picograms per liter (pg/L), equal to 1000 ppt.

| Microbiological (RTCR)             | TT Violation Y or N  | Number of Positive Samples                             | Positive Sample(s) Month & Year | MCL  | MCLG  | Likely Source of Contamination |  |
|------------------------------------|----------------------|--|---------------------------------|------|-------|--------------------------------|--|
| E. Coli                            | N                    | 0  | NA                              | 0    | 0     | Human and animal fecal waste   |  |
| Disinfectants                      | MCL Violation Y or N | Running Annual Average (RAA)                           | Range of All Samples (Low-High) | MRDL | MRDLG | Sample Month & Year            | Likely Source of Contamination                                       |
| Chlorine/Chloramine (ppm)          | N                    | RAA: 1.23  | 0.58-3.20                       | 4    | 4     | Monthly                        | Water additive used to control microbes                              |
| Disinfection By-Products           | MCL Violation Y or N | Running Annual Average (RAA) OR Highest Level Detected | Range of All Samples (Low-High) | MCL  | MCLG  | Sample Month & Year            | Likely Source of Contamination                                       |
| Total Trihalomethanes (TTHM) (ppb) | N                    | Highest: 8.5   | 8.1-8.9                         | 80   | N/A   | August 2024                    | Byproduct of drinking water disinfection                             |
| Lead & Copper                      | MCL Violation Y or N | 90 <sup>th</sup> Percentile                            | Number of Samples Exceeding AL  | AL   | ALG   | Sample Month & Year            | Likely Source of Contamination                                       |
| Copper (ppm)                       | N                    | 0.025  | 0                               | 1.3  | 1.3   | August 2023                    | Corrosion of household plumbing systems; erosion of natural deposits |
| Radionuclides                      | MCL Violation Y or N | Running Annual Average (RAA) OR Highest Level Detected | Range of All Samples (Low-High) | MCL  | MCLG  | Sample Month & Year            | Likely Source of Contamination                                       |
| Alpha Emitters (pCi/L)             | N                    | Highest: 1.6   | 1.1-1.6                         | 15   | 0     | 2023                           | Erosion of natural deposits  |
| Combined Radium-226 & -228 (pCi/L) | N                    | Highest: 1.5   | 0-1.5                           | 5    | 0     | 2023                           | Erosion of natural deposits  |

| Inorganic Chemicals (IOC)  | MCL Violation Y or N | Running Annual Average (RAA) <u>OR</u> Highest Level Detected | Range of All Samples (Low-High) | MCL | MCLG | Sample Month & Year | Likely Source of Contamination  |
|----------------------------|----------------------|---|---------------------------------|-----|------|---------------------|---|
| Arsenic <sup>1</sup> (ppb) | N                    | Highest: 7.7  | NA                              | 10  | 0    | May 2024            | Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes                    |
| Barium (ppm)               | N                    | Highest: 0.015  | NA                              | 2   | 2    | May 2024            | Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits                                |
| Chromium (ppb)             | N                    | Highest: 6.9  | NA                              | 100 | 100  | May 2024            | Discharge from steel and pulp mills; Erosion of natural deposits  |
| Fluoride (ppm)             | N                    | Highest: 0.31   | NA                              | 4   | 4    | May 2024            | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Nitrate <sup>2</sup> (ppm) | N                    | Highest: 2.46   | 1.7-2.46                        | 10  | 10   | May & August 2024   | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits                               |
| Sodium (ppm)               | N                    | 15  | NA                              | N/A | N/A  | May 2024            | Erosion of natural deposits   |

<sup>1</sup> **Arsenic** is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

| Volatile Organic Chemicals (VOC) | MCL Violation Y or N | Running Annual Average (RAA) <u>OR</u> Highest Level Detected | Range of All Samples (Low-High) | MCL | MCLG | Sample Month & Year | Likely Source of Contamination                 |
|----------------------------------|----------------------|---|---------------------------------|-----|------|---------------------|--|
| Xylenes (ppm)                    | N                    | 0.0019  | 0-0.0019                        | 10  | 10   | Quarterly 2024      | Discharge from petroleum or chemical factories |

All contaminants listed below were tested for and were NOT found in our water. These contaminants are considered Non-Detect or not present:

**Synthetic Organic Compounds (Last tested July 2022):** 2,4-D, 2,4,5-TP (a.k.a. Silvex), Acrylamide, Alachlor, Atrazine, Benzo (a) pyrene (PAH), Carbofuran, Chlordane, Dalapon, Di (2-ethylhexyl) adipate, Di (2-ethylhexyl) phthalate, Dibromochloropropane, Dinoseb, Diquat, Dioxin [a.k.a. 2,3,7,8-TCDD], Endothall, Endrin, Epichlorohydrin, Ethylene dibromide, Glyphosate, Heptachlor, Heptachlor epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Lindane, Methoxychlor, Oxamyl (a.k.a. Vydate), PCBs (Polychlorinated biphenyls), Pentachlorophenol, Picloram, Simazine, Toxaphene

**Volatile Organic Compounds (Tested Quarterly in 2024):** Benzene, Carbon tetrachloride, Chlorobenzene, o-Dichlorobenzene, p-Dichlorobenzene, 1,2-Dichloroethane, 1,1-Dichloroethylene, cis-1,2 Dichloroethylene, trans-1,2-Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene, Styrene, Tetrachloroethylene, 1,2,4-Trichlorobenzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, Toluene, Vinyl Chloride

**Inorganic Chemicals (Last tested May 2024):** Antimony, Asbestos, Beryllium, Cadmium, Cyanide, Mercury, Nitrite, Selenium, Thallium

**Lead (Last tested August 2023):** All 10 Lead/Copper sample locations tested in 2023 were "Non-Detect" for lead.

### Water Quality Table – Unregulated Contaminants

*(Applies to Water Systems that were tested for the PFAS group of contaminants in the year of the CCR, but did not participate in UCMR5 testing. Please delete section if does not apply)*

Your drinking water was sampled between [DATES] for the presence and concentration of 29 different per- and polyfluoroalkyl substances, some known by the acronyms PFAS, PFOA, PFNA, PFHxS, PFBS, and GenX, a group of contaminants in the final stages of becoming regulated by the EPA. PFAS are man-made chemicals that are resistant to heat, water, and oil. They have been used since the 1940s to manufacture various consumer products, including fire-fighting foam and stain resistant, water-resistant, and nonstick items. Many PFAS do not break down easily and can build

up in people, animals, and the environment over time. Scientific studies have shown that exposure to certain PFAS can be harmful to people and animals, depending on the level and duration of exposure.

To learn more about this group of chemicals, we encourage you to visit the ADEQ website at <https://www.azdeq.gov/pfas-resources>. You may also read the ADEQ-provided “PFAS 101 Fact Sheet” or view ADEQ’s Introduction to PFAS video on YouTube at <https://www.youtube.com/watch?v=t44kSh0uKXE>

| Per- and Polyfluoroalkyl Substances | Highest Level Detected | Range of All Samples | Proposed MCL |
|-------------------------------------|------------------------|----------------------|--------------|
| PFOA (in parts per trillion)        | 8.77                   | 3.09-8.77            | 4.0 ppt      |
| PFOS (in parts per trillion)        | ND                     | ND                   | 4.0 ppt      |
| PFNA (in parts per trillion)        | ND                     | ND                   | 10 ppt       |
| PFHxS (in parts per trillion)       | 6.93                   | 3.12-6.93            | 10 ppt       |
| PFBS (in parts per trillion)        | 3.34                   | 3.24-3.34            | N/A*         |
| GenX (in parts per trillion)        | ND                     | ND                   | 10 ppt       |
| Calculated Hazard Index (HI)        |                        |                      | 1 (no units) |

\* Hazard Index  
Hazard Index approach that the health associated with certain PFAS in finished drinking water. Low levels of multiple PFAS that individually would not likely result in adverse health effects may pose health concerns when combined in a mixture. The Hazard Index MCL represents the maximum level for mixtures of PFHxS, PFNA, HFPO-DA, and/or PFBS allowed in water delivered by a public water system. A Hazard Index greater than 1 requires a system to take action.

or HI: The is an determines concerns mixtures of

*(Applies to Water Systems that participated in the UCMR5 program in the year of the CCR, delete section if does not apply).*

**Water Quality Table - Unregulated Contaminant Monitoring Rule (Required Reporting)**

Report results for all contaminants detected at or above the Minimum Reporting Level, including the average result for each contaminant and the range of all samples taken for each contaminant. **Report all results in parts per trillion (or ng/L).** To convert values from parts per billion (or ug/L), multiply by 1,000. For assistance with accessing and understanding your data, please refer to the document “Instructions for Accessing Results from UCMR 5” on the [UCMR Occurrence Data webpage](#). Specific UCMR 5 analytical results can be downloaded as an Excel file (.xlsx) using the [UCMR 5 Data Finder](#). For more information, visit: <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule>

| Twenty-nine Per- and Polyfluoroalkyl Substances (In parts per trillion) | Detected (Y/N) | Average of Results (ppt) | Range of All Samples (Low-High) | Minimum Reporting Level (ppt) | Analytical Methods |
|---|----------------|--------------------------|---------------------------------|-------------------------------|--------------------|
| 11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)      | N              |                          |                                 | 5                             | EPA 533            |
| 1H, 1H, 2H, 2H-perfluorodecane sulfonic acid (8:2 FTS)                  | N              |                          |                                 | 5                             | EPA 533            |
| 1H, 1H, 2H, 2H-perfluorohexane sulfonic acid (4:2 FTS)                  | N              |                          |                                 | 3                             | EPA 533            |
| 1H, 1H, 2H, 2H-perfluorooctane sulfonic acid (6:2 FTS)                  | N              |                          |                                 | 5                             | EPA 533            |
| 4,8-dioxa-3H-perfluorononanoic acid (ADONA)                             | N              |                          |                                 | 3                             | EPA 533            |
| 9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)           | N              |                          |                                 | 2                             | EPA 533            |
| hexafluoropropylene oxide dimer acid (HFPO-DA) (GenX)                   | N              |                          |                                 | 5                             | EPA 533            |
| nonafluoro-3,6-dioxaheptanoic acid (NFDHA)                              | N              |                          |                                 | 20                            | EPA 533            |
| perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)                      | N              |                          |                                 | 3                             | EPA 533            |
| Perfluoro-3-methoxypropanoic acid (PFMPA)                               | N              |                          |                                 | 3                             | EPA 533            |
| Perfluoro-4-methoxybutanoic acid (PFMBA)                                | N              |                          |                                 | 4                             | EPA 533            |
| Perfluorobutanoic acid (PFBA)   | N              |                          |                                 | 5                             | EPA 533            |
| Perfluorodecanoic acid (PFDA)   | N              |                          |                                 | 3                             | EPA 533            |
| Perfluorododecanoic acid (PFDoA)  | N              |                          |                                 | 3                             | EPA 533            |
| Perfluoroheptanesulfonic acid (PFHpS)                                   | N              |                          |                                 | 3                             | EPA 533            |

|   |                       |                |  |                  |                                     |
|---|-----------------------|----------------|--|------------------|-------------------------------------|
| Perfluoroheptanoic acid (PFHpA)                           | N                     |                |  | 3                | EPA 533                             |
| Perfluorohexanesulfonic acid (PFHxS)                      | Y                     | 5.74           | 5.74                                   | 3                | EPA 533                             |
| Perfluorohexanoic acid (PFHxA)                            | Y                     | 8.00           | 8.00                                   | 3                | EPA 533                             |
| Perfluorononanoic acid (PFNA)                             | N                     |                |  | 4                | EPA 533                             |
| Perfluorooctanesulfonic acid (PFOS)                       | N                     |                |  | 4                | EPA 533                             |
| Perfluorooctanoic acid (PFOA)                             | Y                     | 7.74           | 7.74                                   | 4                | EPA 533                             |
| Perfluoropentanesulfonic acid (PFPeS)                     |                       |                |  | 4                | EPA 533                             |
| Perfluoropentanoic acid (PFPeA)                           |                       |                |  | 3                | EPA 533                             |
| Perfluoroundecanoic acid (PFUnA)                          |                       |                |  | 2                | EPA 533                             |
| n-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)  | N                     |                |  | 5                | EPA 537.1                           |
| n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA) | N                     |                |  | 6                | EPA 537.1                           |
| Perfluorotetradecanoic acid (PFTA)                        | N                     |                |  | 8                | EPA 537.1                           |
| Perfluorotridecanoic acid (PFTTrDA)                       | N                     |                |  | 7                | EPA 537.1                           |
| <b>One Metal</b>  | <b>Detected (Y/N)</b> | <b>Average</b> | <b>Range of All Samples (Low-High)</b> | <b>MRL (ppb)</b> | <b>Analytical Methods</b>           |
| Lithium (ppb)   |                       |                |  | 9 µg/L           | EPA 200.7, SM 3120 B, ASTM D1976–20 |

### Violation Summary

| Violation Type  | Explanation, Health Effects | Time Period | Corrective Actions |
|---|-----------------------------|-------------|--------------------|
| Our System is pleased to announce we have no violations to report for 2024. |                             |             |                    |

### Health Effects Information

While your drinking water meets EPA’s standard for arsenic, it does contain low levels of arsenic. EPA’s standard balances the current understanding of arsenic’s possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a the mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

### System Monitoring and Testing

The data presented in the report are from the most recent round of sampling. Not all contaminants are tested each year. Chlorine residual samples are tested daily, microbiological samples are tested monthly. Lead and copper are tested on a 3 year cycle. VOC’s, IOC’s and SOC’s are tested on a 9 year cycle. The 90<sup>th</sup> percentile is arrived at by taking the highest two results adding them together and dividing by two.

### In Conclusion

We have learned through our monitoring and testing that some contaminants have been detect. The Town is working to select treatment methods that will bring levels below the MCL. The Town of Chino Valley Utilities department works to provide top quality water to every customer. We ask that all our customers help us protect our water sources, which is at the heart of our community